



OFFICE OF THE FIRE OFFICER,
NORTHERN RANGE, SAMBALPUR

Phone- 0663-2546050, Fax- 0663-2546056, E-mail- rangefireofficersbp@gmail.com

FORM-V

FIRE SAFETY CERTIFICATE

(See rule-13 (3) of the Odisha Fire Prevention and Fire Safety Rules, 2017)

File No. G-101-2019

Certificate No.15/2020/NR (FPW)

Dated 24.03.2020

This Certificate is valid up to 23.03.2022

(Apply for renewal at least three months before expiry)

Certified that the Indian Public School, Sambalpur (name of building/premises) situated at (address) Sambalpur Town, Unit-11, Khetrajpur, Dist- Sambalpur consisting of total two number of blocks were inspected by officers of the Fire Service on 14.07.2019 & 02.02.2020 in presence of representative of applicant and out of which Block-A has been found to comply with the fire prevention and safety requirements in accordance with the Odisha Fire Prevention and Fire Safety Rules, 2017 read with Odisha Fire Prevention and Fire Safety (Amendment) Rules-2019 and that its various floors of Block-A is fit for occupancy or usage as noted hereunder against each subject to compliance to the conditions as prescribed herein below.

1. Ground to 3 rd floor	--- Usage ---	Block-A, Educational (School)
------------------------------------	---------------	-------------------------------

CONDITIONS:

1. Fire prevention and safety measures and appliances, availability of water supplies and means of access thereto etc provided in the building or premises, should be maintained by the occupier (s) in best repairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
2. The set backs, driveways, entrance gates, exits, corridors and escape ways should not be changed, obstructed or modified in any way.
3. The occupier (s) shall train all staff and occupants periodically to make them well conversant in use and operation of the fire prevention and safety measures.
4. Fire drills/rehearsals should be organized at least once in six months by involving Local Fire Stations.
5. Photocopies of this Certificate should be framed and displayed at all conspicuous places in all lobbies/ corridors in all floors of all Towers/ Blocks of building/premises.


Fire Officer,

Northern Range, Sambalpur

Dtd. 24/03/2020

Memo No. 2504 /NR (FPW)

Copy to Sri Keshab Kumar Dalmia, S/o- Madanlal Dalmia, Poddar Colony, Khetrajpur, Sagar, Dist- Sambalpur-768003 for information.


PRINCIPAL
Indian Public School
Remed-Khetrajpur Road,
Sambalpur-768006 (Odisha)


Fire Officer,
Northern Range, Sambalpur




OFFICE OF THE ASST. FIRE OFFICER, SAMBALPUR

To Whom it may so concern

Certified that on the basis of request, I have checked the Fire Extinguishers of Indian Public School, at - Remed- Khetrajpur road, Sambalpur on 13/11/2016 and found that all were working condition during visit. Details are as follows;-

- | | |
|---|--------|
| (1) DCP type Fire Extinguisher (cap 05Kg) | 06 nos |
| (2) Water type CO2 Fire Extinguisher (cap 09 lts) | 01 nos |
| (3) CO2 Fire Extinguisher | 02 nos |

Here with it is suggested that, every fire extinguishers must be periodically cleaned, maintained, tested & charged etc as per norms (IS:2190) to upkeep its reliability at all times. Besides working staffs should be given due training on use of fire extinguishers in regular interval under expert hand to deal in case of emergency.



17.11.16
Asst. Fire Officer
Sambalpur fire Station

Memo no- 4809 /SBP FS

Dtd. 17.11.2016

Copy submitted to the Manager, Indian Public School, Sambalpur for Information & necessary action .


PRINCIPAL
Indian Public School
Remed-Khetrajpur Road,
Sambalpur-768006 (Odisha)


17.11.16
Asst. Fire Officer
Sambalpur fire Station

Asst. Fire Officer
SAMBALPUR